



Declaration of Conformity

Registration No: 220514.AFSDOC.01

Issue Date: May 22, 2014

SONOAFS-ALU SHINE

insulated flexible air duct

was tested pursuant to applicable test procedures

and complies with the requirements of

EN 13180: 2001

TS EN 13180: 2006

Manufacturer : **AFS BORU SANAYI A.S.**

Ivedik O.S.B. 1468 Cad. No:153 Ostim 06370 Ankara / Turkey

Diameter Range : Ø 102 mm – Ø 305 mm

Test Results : Diameter class : B

Air tightness class : C

Positive rated pressure : 3000 Pa

Negative rated pressure : - 150 Pa

Minimum bending radius : 0.5 D

Sag : 4° to 12°

Crushing strength : compressed 12 to 15 kg. and uncompr. 1.0 to 1.4 kg.

Authorized by :

Zahid Poyraz

General Coordinator